10N ·0 8 5010

Cook



2010 MAY 1 1 PM 1: 58

11117 Mockingbird Drive Omaha, Nebraska 68137 www.atcassociates.com Phone: 402.697.9747

Fax: 402.697.9170

April 9, 2010

Tennessee Dept. of Environment & Conservation Div. of Air Pollution Control 9th Floor, L&C Annex 401 Church Street Nashville, TN 37243-1531

RE: U.S. Cellular® - Emergency Generator Air Permit Applications

Dear Sir or Madam:

ATC Associates, Inc. was retained by U.S. Cellular[®] to complete air permit applications for their emergency generators within the State of Tennessee pursuant to APC Rule Ch. 1200. Upon review of U.S. Cellular's databases and through confirmation with their Network Field Engineers, ATC determined that U.S. Cellular currently has fifteen (15) generators within the State of Tennessee that are required to obtain air permits.

Attached are the Air Permit Application Forms (Form APC20, Form APC21&24 and APC22) for the fifteen (15) generators along with a check in the amount of \$1,500.00 (\$100.00/facility) for the permit fees. Also attached is a list of the fifteen (15) facilities with generators.

If you should have any questions, please do not hesitate to call me at (515) 981-3216.

Sincerely.

ATC ASSOCIATES INC.

Mike Freese, REM Sr. Project Manager

Attachments

cc: Doug Zabrin – U.S. Cellular®
Brad Summers – U.S. Cellular®
Dale Mattson – U.S. Cellular®
Jerry Williams – U.S. Cellular®
Mark Clark – U.S. Cellular®
Tony Chandler – U.S. Cellular®

Permit Required Facilities


Site #	Site Name	Site Address	Site City	Site State	Site Zip	Site County	Site Contact	Contact Phone	Gen. Mfr.	Gen. Model	Gen. Size (KW)	Generator Fuel Type
	411316 RATTLESNAKE											DSL -
411316	DT	347 Tower Road	Gatlinburg	TN	37738	Sevier	Brad Summers	865.705.7600	Cummins	DGGD	35	Diesel
	860327 HARTSVILLE	136 Morrison Street	Hartsville	TN	37074	Trousdale	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
	SPRINGS	Rd.	Red Boiling Springs	TN	37150	Macon	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860338	860338 WESTSIDE	461 Green Grove Rd.	Lafayette	TN	37083	Macon	Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860319		8638 Sticking Creek Rd.	Pioneer	TN	37847	Campbell	Jerry Williams	865.679.4446	Kohler	50REOZJC	37	DSL - Diesel
860348	860348 PEAVINE	653 Eroh Rd.	Crossville	TN	38571	Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860359	860359 ROBBINS	East Robbins Rd.	Robbins	TN	37852	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860362	860362 PINEY	252 Old Harriman Hwy.	Harriman	TN	37748	Roane	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860367	860367 CORDELL	8787 James Baker Highway	Huntsville	TN	37756	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860368	860368 MOFFIT	4496 Straight Fork Road	Pioneer	TN	37847	Scott	Mike Clark	931,979.0041	Kohler	30REOZJC	27	DSL - Diesel
860381	860381 STEPHENS	180 Tree Top Lane	Coalfield	TN	37719	Morgan	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
411346	411346 DOUGLAS DAM	1443 Holbert Road	Dandridge	TN	37725	Sevier	Tony Chandler	865.679.0010	Kohler	50REOZJC	37	DSL - Diesel
860354	860354 CRAB ORCHARD	384 Godsey Road	Crab Orchard	TN	37723	Cumberland	Mike Clark	931.979.0041	Kohler	30REOZJC	27	DSL - Diesel
860358	860358 GLEN MARY	593 Huckelby Road	Robbins	TN	37852	Scott	Mike Clark	931,979.0041	Kohler	50REOZJC	37	DSL - Diesel
860345	860345 TANSI	490Vandiver Rd.	Crossville	TN	38571	Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel

0860	05/06/2010	R 0000199217		1500009260
INVOICE NUMBER	DATE	AMOUNT	DISCOUNT	NET AMOUNT
050510 AIR PERMIT FEES	05/05/2010 S	\$1.500,00 2010 HAY 1 I	PH 1: 58	\$1,500.00

Tennessee RSA No. 3 LP 8410 W Bryn Mawr Ave Suite 700 Chicago, IL 60631-3415

Tennessee RSA No. 3 LP 8410 W Bryn Mawr Ave Suite 700 Chicago, IL 60631-3415

> DATE May 06, 2010



0860 0000199217

MEMOVE DECEMBER ALONG THE PERFORATION

1500009260 BANK OF AMERICA

2-3 710 IL

PAY ONLY \$1,500.00

VOID IF NOT CASHED WITHIN 180 DAYS OF ISSUE

One thousand five hundred and 00/100 Dollars

PAY TO THE ORDER OF

State of Tennessee Dept of Environment - Conservation 401 Church Street NASHVILLE TN 37243

1500009260# #1071000039#1 5800963430#

0000199217

Remove this stub before cashing. Fold, crease, and tear along perforation.

1500009260

Tennessee RSA No. 3 LP 8410 W Bryn Mawr Ave Suite 700

Chicago, IL 60631-3415

AND OBJECT CHAIN.

HER OBJECT TO

BRANCE

BRAN

SUS. Cellular.

State of Tennessee Dept of Environment - Conservation 401 Church Street NASHVILLE TN 37243

Call 1-800-PICK-UPS® (1-800-742-5877) or visit ups.com®

- For UPS Next Day Air services, there is no weight limit for envelopes containing letters, business correspondence, urgent documents, and electronic media. When a UPS Next Day Air service is selected, UPS subject to the corresponding rates for the applicable weight. Express Envelopes containing items other than those listed above are
- containing sensitive personal information. Express Envelopes are not recommended for shipments of electronic media
- or number of pages you can enclose. For UPS Worldwide Express, the UPS Express Envelope may be used only for documents of no commercial value. There is no limit on the weight
- Do not use UPS 2nd Day Air services to send letters weighing over
 13 ounces in this envelope. For UPS 2nd Day Air services, UPS Express
 Envelopes weighing one pound or more are subject to the corresponding rates for the applicable weight.

tegal Size TOURSE THE TOURSE TO THE TOURSE

eddas, hi ieddan to seiddi, of fa chlip in amother reciplent. See seas s<mark>asoudi</mark>tos so llopainos. The later proper words by white with the territory of the conditions of

Decision Greens

our pursuit of sustainable business practices worldwide. For example, this envelope is made from 100% recycled material and is both reusable and recyclable. Decision Green is UPS's environmental platform, reflecting

100% Recycled fiber 80% Post-Consumer

SHIP TO:
TENNESSEE DEPT OF ENVIROMENTAL
DIV OF AIR POLLUTION CONTROL
7TH FLOOR L&C ANNEX
401 CHURCH ST. NASHVILLE TN 37219-2310 2 LBS 1 OF 1

OPS CampusShip: Lab



Page I of 2

pe is for use ving services:

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone: (615) 532-0554 FAX: (615) 532-0614 FAX:

2010 MAY 1 1 PM 1: 59

PERMIT APPLICATION

		IN DUPLICATE FO	R EACH EMISS	ION SO	URCE. ATTACH APPROPRIATE SOURCE
DESCRIPTION FOR ORGANIZATION	MS. N'S LEGAL NAME			1///	APC COMPANYPOINT NO.
					510-0000
IS Cellular MAILING ADDR	RESS (ST/RD/P.O. BOX)		111	APC LOG/PERMIT NO.
410 W. Bryn Mawr Av		,		APC	63693
CITY	chie, date 300	STATE	ZIP CODE	<u> </u>	PHONE WITH AREA CODE
hicago		Illinois	60631		773-399-6899
. PRINCIPAL TEC	CHNICAL CONTACT	<u></u>			PHONE WITH AREA CODE
ohn Glatz/US Cellular	Mike Freese/ATC As	ssociates			773-399-6899 515-981-3216
SITE ADDRESS	(ST/RD/HWY)				COUNTY NAME
	d (Site known as 860333				Macon
CITY OR DISTAI	NCE TO NEAREST TO	WN	ZIP CODE 37150		PHONE WITH AREA CODE 931-979-2499 Dale Mattson – Network Field Eng.
ed Boiling Springs		.,			951-979-2499 Date Waltsoft - Network Field Eng.
EMISSION SOU IDENTIFIES THI	RCE NO. (NUMBER W	HICH UNIQUELY	PERMIT RENEV	WAL NO (X)	
S-1	S SOURCE)		120()	110 (A)	,
BRIEF DESCRII	PTION OF EMISSION	SOURCE			
	(Y7.3.1. N.A. 3.1.5)	ODEOGIO)			•
Backup Emergency Ger					
	UT REQUESTED				
	IIT REQUESTED N STARTING DATE	COMPLETION	LAST PERMIT		EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM	N STARTING DATE	COMPLETION DATE	LAST PERMIT	Γ	EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM CONSTRUCTION (X)	N STARTING DATE Installed 10/09	DATE	NUMBER		
. TYPE OF PERM	N STARTING DATE	1			EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM CONSTRUCTION (X)	Installed 10/09 DATE CONSTRU-	DATE	NUMBER LAST PERMIT NUMBER	r	
. TYPE OF PERM CONSTRUCTION (X) OPERATING	N STARTING DATE Installed 10/09 DATE CONSTRUCTION STARTED	DATE	NUMBER LAST PERMIT	r	
. TYPE OF PERM CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE	DATE	NUMBER LAST PERMIT NUMBER LAST PERMIT	r	EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION	DATE DATE COMPLETED	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER	Γ	EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION	DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER	Γ	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE F	DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER	Γ	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE F	DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER	Γ	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE F	DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER	Γ	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PI	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE FERMIT APPLICATION	DATE DATE COMPLETED BEEN MADE TO THIS N.	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT O	Γ R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PI	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE FERMIT APPLICATION	DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT O	Γ R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR DATE
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PROPERATING PROPERATING PROPERATING PROPERATING PROPERATION PRO	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE BERMIT APPLICATION	DATE DATE COMPLETED BEEN MADE TO THIS N.	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT O	Γ R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PI	Installed 10/09 DATE CONSTRUCTION STARTED Installed 10/09 TRANSFER DATE AST LOCATION ANGES THAT HAVE BERMIT APPLICATION	DATE DATE COMPLETED BEEN MADE TO THIS SIGNED BEFORE IT	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT O	T R OPERA	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR DATE

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone:(615) 532-0554 ... FAX: (615) 532-0614

2010 MAY 1 1 PM 1: 59

PROCESS OR FUEL BURNING SOURCE DESCRIPTION

APC21(& 24)

PL	EASE TYPE OR PRINT, SUBMI	T IN DUP	LICATE AND	ATTACH TO TI	HE PERMIT A	APPLICA	ATIC	DN.
1.	ORGANIZATION NAME					///	AP	C COMPANY-POINT NO.
US	Cellular					FOR	٠	
2.	EMISSION SOURCE NO. (AS O	N PERMIT	T APPLICATIO	N)	SIC CODE	1///	AP	C PERMIT/LOG NO.
ES-	1				4812	APC		
3.	DESCRIPTION OF PROCESS OR	FUEL BU	RNING UNIT					
Bac	kup Emergency Generator (Kohler M	odel 50REC	OZJC)					
	NORMAL OPERATION:	HOURS/I	DAY DAYS	WEEK	WEEKS/YE	FAR	L D4	AYS/YEAR
4.	→ Emergency generator is	110013/1	DAT DATS	AA ESESIK	WEEKSTE			115/1L/M
exe	rcised on a periodic basis							
5.	PERCENT ANNUAL	DECFEI	B. MARC	H-MAY	JUNE-AUG	ì.	SE	PTNOV.
	THROUGHPUT: →	25%	6	25%	25%	, h		25%
6.	TYPE OF PERMIT APPLICATIO	<u> </u>	<u> </u>	20,0			(0	CHECK BELOW ONE ONLY)
	PROCESS SOURCE: APPLY FOR		ATE PERMIT FO	OR EACH SOURCE	E. (CHECK A	T	Ė	
	RIGHT, AND COM						ļ	()
	PROCESS SOURCE WITH IN-P			TS OF COMBUST ARATE PERMIT F				()
				ES 7, 8, AND 10 TH		JKCE.		()
	NON-PROCESS FUEL BURNIN					NTACT	 	
				ORM FOR EACH				(X)
				POINT DESCRIPT: AND COMPLETE I				
7.	TYPE OF OPERATION: CONTI			ATCH	NORMAL		NO	ORMAL BATCHES/DAY
		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	27.	11011	TIME			
	()	()			<u> </u>	
8.	PROCESS MATERIAL INPUTS A IN-PROCESS SOLID FUELS	AND	DIAGRAM* REFERENCE	DESIGN	S (POUNDS/H			(FOR APC USE ONLY) SCC CODE
	A.		REFERENCE	DESIGN	ACTO	AL.	1	3cc code
							1	
	В.			<u> </u>			1	
							1	
	C.			<u> </u>			1	
	.						1	
	D.						+-	
	2.						1	
	E						+-	
	E.						1	
	F.						+,	
	k'i						1/	
	C						 	
	G.		İ				1/	
							 	
			TOTALS				1/	
				1			Ι΄.	

^{*} A SIMPLE PROCESS FLOW DIAGRAM MUST BE ATTACHED.

9. BOILER (BOILER OR BURNER DATA: (COMPLETE LINES 9 TO 14 USING A SEPARATE FORM FOR EACH BOILER)						
BOILER NUMBER ES-1	STACK NUMBER** EP-1	TYPE OF FIRING***	RATED BOILER HORSEPOWER	RATED INPUT CAPACITY (10 ⁶ BTU/HR)	OTHER BOILER RATING (SPECIFY CAPACITY AND UNITS) 37 kilowatt		
BOILER SERIAL NO. DATE CONSTRUCTED 2218499 October 2009		DATE OF LAST M	L ODIFICATION (EX	L PLAIN IN COMMENTS BELOW).			

^{**} BOILERS WITH A COMMON STACK WILL HAVE THE SAME STACK NUMBER.


*** CYCLONE, SPREADER (WITH OR WITHOUT REINJECTION), PULVERIZED (WET OR DRY BOTTOM, WITH OR WITHOUT REINJECTION), OTHER STOKER (SPECIFY TYPE), HAND FIRED, AUTOMATIC, OR OTHER TYPE (DESCRIBE BELOW IN COMMENTS).

10. FUEL DATA: (COMPLET	TE FOR A PROCESS S	OURCE WITH	IN-PROCESS I	FUEL OR A N	ON-PRO	CESS FUEL BURNI	ING SOURCE)
PRIMARY FUEL TYPE (S	PRIMARY FUEL TYPE (SPECIFY) Diesel Fuel)
FUELS USED	ANNUAL USAGE	HOURLY	Y USAGE	%	%	BTU VALUE	(FOR APC ONLY)
		DESIGN	AVERAGE	SULFUR	ASH	OF FUEL	SCC CODE
NATURAL GAS:	10° CUFT	CUFT	CUFT	1111	/ / /		
#2 FUEL OIL: Diesel Fuel	10 ³ GAL	GAL:4.3	GAL: 3.6		1 1		
	<100 gal./year	gal./hr. @ full standby	gal./hr. @ full prime	<0.5%	/ /	140,000/gal.	20200102
#5 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / / /		
#6 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / / /		
COAL:	TONS	LBS	LBS				
WOOD:	TONS	LBS	LBS	1111	/ / / / /		
LIQUID PROPANE:	10 ³ GAL	GAL	GAL	1111	/ / / / /		
OTHER (.SPECIFY TYPE & UNITS.):					,		

11. IF WOOD IS USED AS A FUEL, SPECIFY TYPES AND ESTIMATE PERCENT BY WEIGHT OF BARK

12.	IF WOOD IS USED WITH OTHER	: FUELS, SPECIFY PERCENT BY WEIGHT	T OF WOOD CHARGED TO THE BURNER.
-----	----------------------------	------------------------------------	----------------------------------

13.	COMN	MENTS:	Process	Flow	Diagram below.	



	<i></i>	
14. SIGNATURE	Steep	DATE 4/30/2010
7-000	3	

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone: (615) 532-0554 FAX: (615) 532-0614

2010 MAY 1 1 PM 1: 59

EMISSION POINT DESCRIPTION

APC 22

PLEASE TYPE OR PRINT ATTACH TO THE PERMI			ATE FOR EACH STA	CK OK EMISSION	roint.		
1. ORGANIZATION NAME		······································			///	APC COMPA	NY POINT NO.
US Cellular					FOR		
2. EMISSION SOURCE NO	(FROM APPL	ICATION)	FLOW DIAGRAM PO	INT NUMBER	111	APC SEQUEN	ICE NO.
ES-1			EP-1		APC		
3. LOCATION:	LATITUDE		LONGITUDE	UTM VERTICAL	I	UTM HORIZO	NTAL
 →	36.537765		-85.862550				
4. BRIEF EMISSION POIN		ON (ATTACH A		RIATE):		DISTANCE T	
Exhaust for emergency generate	nr.					PROPERTY L	INE (FT)
Exhaust for emergency generate	,,					Remote Cell lo	ocation >50ft.
COMPLETE LINES & AND C	T DIFFERENCE	EDOM THAT	NI THE PROCESS OF	THE DUDNING COLU	DOE DESCRIPTION	NI (ADC 21)	
COMPLETE LINES 5 AND 6 I 5. NORMAL	HOURS/DAY		DAYS/WEEK	WEEK/YEAR	RCE DESCRIPTIO	DAYS/YEAR	
OPERATION:			and the first of the second of	arana a Add AAN			
→	Emergency ge exercised on a						
6. PERCENT ANNUAL	DECFEB.		MARCH-MAY	JUNE-AUG.		SEPTNOV.	***************************************
THROUGHPUT: →	2.	5%	25%	25%			25%
7. STACK OR EMISSION	HEIGHT AB		DIAMETER	TEMPERATURE	% OF TIME	DIRECTION	
POINT DATA:			(FT)	(°F)	OVER 125°F	(UP, DOWN OR	
\rightarrow			z.	HORIZONTAL) Vertical			
DATA AT EXIT	FLOW (ACTUAL		VELOCITY	MOISTURE		MOISTURE	
CONDITIONS:	FT ³ /MIN.)		(FT/SEC)	(GRAINS/FT³)		(PERCENT)	
	456						
DATA AT STANDARD CONDITIONS:	FLOW (DRY FT³/MIN)	STD.	VELOCITY (FT/SEC)	MOISTURE (GRAINS/FT³)		MOISTURE (PERCENT)	
CONDITIONS.	I'I /WIIN)		(F1/3EC)	(GRAINS/F1)		(FERCENT)	
	423	10	TILL DAMESTON		T		7
8. AIR CONTAMINANTS	EMISSIONS		TUAL EMISSIONS CONCENTRATION	AVG.	EMISSIONS*	CONTROL	CONTROL
	AVERAGE			(TONS/YR)	EST. METHOD	DEVICES*	EFFICIENCY%
PARTICULATES	0.15	0.18	**	0.05	3		
SULFUR	0.13	0.10	***	0.03	3		
DIOXIDE	0.14	0.17		0.04	3	·	
CARBON MONOXIDE	0.47	0.56	PPM	0.14	3	į	
ORGANIC			PPM				
COMPOUNDS NITROGEN	0.18	0.21	PPM	0.05	3		
OXIDES	2.17	2.60	A A A A A A A A A A A A A A A A A A A	0.65	3		
FLUORIDES				<0.01			
OTHER(SPECIFY)	Above emissions	Above emissions		Emissions above based on 500hrs/yr	Above based on SCC 20200102		
	based on full prime	based on full standby		and full standby.			

9.	CHECK TYPES OF MONITORING AND RECORDING INSTRUMENTS THAT ARE ATTACHED:
	OPACITY MONITOR (), SO2 MONITOR (), NOX MONITOR (), OTHER (SPECIFY IN COMMENTS) (X)
10.	COMMENTS
Ho	ur meter

A Samuel	A STATE OF THE STA	
11. SIGNATURÉ	10/401	DATE 4/30/2010
	Mehrel Steel	4/30/2010

REFER TO THE BACK OF THE PERMIT APPLICATION FORM FOR ESTIMATION METHOD AND CONTROL DEVICE CODES. EXIT GAS PARTICULATE CONCENTRATION UNITS: PROCESS — GRAINS/DRY STANDARD FT3 (70°F); WOOD FIRED BOILERS —

GRAINS/DRY STANDARD FT3 (70°F); ALL OTHER BOILERS — LBS/MILLION BTU HEAT INPUT.

*** EXIT GAS SULFUR DIOXIDE CONCENTRATIONS UNITS: PROCESS — PPM BY VOLUME, DRY BASES; BOILERS — LBS/MILLION BTU HEAT INPUT.

KOHLER POWER SYSTEMS


208-600 V

Diesel



Ratings Range

		OU FIZ
Standby:	kW	37-50
•	kVA	37-63
Prime:	kW	33-45
	kVA	33-56



Generator Set Ratings

				_			
				130°C Rise Standby Rating		105°C Rise Prime Rating	
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps
	120/208	3	60	47/59	163	43/54	149
	127/220	3	60	49/61	161	45/56	148
	120/240	3	60	47/59	141	43/54	129
4P7	120/240	1	60	37/37	154	33/33	138
457	139/240	3	60	50/63	150	45/56	135
	220/380	3	60	40/50	76	36/45	68
	277/480	3	60	50/63	75	45/56	68
	347/600	3	60	40/50	48	36/45	43
	120/208	3	60	50/63	173	45/56	156
	127/220	3	60	50/63	164	45/56	148
	120/240	3	60	50/63	150	45/56	135
4P8	120/240	1	60	47/47	196	43/43	179
400	139/240	3	60	50/63	150	45/56	135
	220/380	3	60	50/63	95	45/56	85
	277/480	3	60	50/63	7 5	45/56	68
	347/600	3	60	50/63	60	45/56	54
4Q10	120/240	1	60	50/50	208	45/45	188

Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
- The generator set and its components are prototype-tested, factory-built, and production-tested.
- The 60 Hz generator set offers a UL 2200 listing.
- The generator set accepts rated load in one step.
- The 60 Hz generator set meets NFPA 110, Level 1, when equipped with the necessary accessories and installed per NFPA standards.
- The generator set complies with ISO 8528-5, Class G2, requirements for transient performance in all generator set configurations. Select the Decision-Maker[®] 550 controller for improved voltage regulation and ISO 8528-5, Class G3, compliance.
- The 60 Hz generator set engine is certified by the Environmental Protection Agency (EPA) to conform to Tier 3 nonroad emissions regulations.
- A one-year limited warranty covers all systems and components. Two-, five-, and ten-year extended warranties are also available.
- Alternator features:
 - The unique Fast-Response[™] Il excitation system delivers excellent voltage response and short-circuit capability using a permanent magnet (PM)-excited alternator.
 - The brushless, rotating-field alternator has broadrange reconnectability.
- · Other features:
 - Controllers are available for all applications. See controller features inside.
 - The low coolant level shutdown prevents overheating (standard on radiator models only).
 - Integral vibration isolation eliminates the need for under-unit vibration spring isolators.

RATINGS: All three-phase units are rated at 0.8 power factor. All single-phase units are rated at 1.0 power factor. Standby Ratings: Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. Ratings are in accordance with ISO-3046/1, BS 5514, AS 2789, and DIN 6271. Prime Power Ratings: Prime power ratings apply to installations where utility power is unavailable or unreliable. At varying load, the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-3046/1, BS 5514, AS 2789, and DIN 6271. For limited running time and base load ratings, consult the factory. Obtain the technical information bulletin (TIB-101) on ratings guidelines for the complete ratings definitions. The generator set manufacturer reserves the right to change the design or specifications without any obligation or liability whatsoever. GENERAL GUIDELINES FOR DERATION: Altitude: Derate 0.5% per 100 m (328 ft.) elevation above 2300 m (7546 ft.). Temperature:

Alternator Specifications

Specifications	Alternator
Manufacturer	Kohler
Туре	4-Pole, Rotating-Field
Exciter type	Brushless, Permanent-Magnet
Leads: quantity, type	12, Reconnectable
Voltage regulator	Solid State, Volts/Hz
Insulation:	NEMA MG1
Material	Class H
Temperature rise	130°C, Standby
Bearing: quantity, type	1, Sealed
Coupling	Flexible Disc
Amortisseur windings	Full
Voltage regulation, no-load to full-load	
Permanent magnet (PM) alternator	±2% Average
550 controller (with 0.5% drift	
due to temperature variation)	3-Phase Sensing, ±0.25%
One-step load acceptance	100% of Rating
Unbalanced load capability	100% of Rated Standby Current
Peak motor starting kVA: 480 V 4P7 (12 lead) 480 V 4P8 (12 lead) 240 V 4Q10 (4 lead)	(35% dip for voltages below) 194 212 155

- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Vacuum-impregnated windings with fungus-resistant epoxy varnish for dependability and long life.
- Superior voltage waveform from a two-thirds pitch stator and skewed rotor.
- Fast-Response[™] II brushless alternator with brushless exciter for excellent load response.

Application Data

E	n	a	i	n	e

Engine	
Engine Specifications	
Manufacturer	John Deere
Engine model	4024HF285B
Engine type	4-Cycle, Turbocharged
Cylinder arrangement	4 Inline
Displacement, L (cu. in.)	2.4 (149)
Bore and stroke, mm (in.)	86 x 105 (3.39 x 4.13)
Compression ratio	18.2:1
Piston speed, m/min. (ft./min.)	375 (1230)
Main bearings: quantity, type	Replaceable Insert
Rated rpm	1800
Max. power at rated rpm, kWm (BHP)	60 (80)
Cylinder head material	Cast Iron
Crankshaft material	Ductile Iron
Valve material:	
Intake	Chromium-Silicon Steel
Exhaust	Stainless Steel
Governor: type, make/model	JDEC Electronic, Level 18, EUP
Frequency regulation, no-load to full-load	Isochronous
Frequency regulation, steady state	±0.25%
Frequency	Fixed
Air cleaner type, all models	Dry

Exhaust

Exhaust System	
Exhaust manifold type	Dry
Exhaust flow at rated kW, m ³ /min. (cfm)	12.0 (423)
Exhaust temperature at rated kW, dry exhaust, °C (°F)	574 (1066)
Maximum allowable back pressure, kPa (in. Hg)	7.5 (2.2)
Exhaust outlet size at engine hookup, mm (in.)	63.5 (2.5)

Engine Electrical

Engine Electrical System	
Battery charging alternator:	
Ground (negative/positive)	Negative
Volts (DC)	12
Ampere rating	70
Starter motor rated voltage (DC)	12
Battery, recommended cold cranking amps (CCA):	
Quantity, CCA rating	One, 640
Battery voltage (DC)	12

Fuel

Fuel System	
Fuel supply line, min. ID, mm (in.)	11.0 (0.44)
Fuel return line, min. ID, mm (in.)	6.0 (0.25)
Max. lift, engine-driven fuel pump, m (ft.)	3.0 (10.0)
Max. fuel flow, Lph (gph)	82 (21.7)
Fuel prime pump	Manual
Fuel filter	
Secondary	5 Microns @ 98% Efficiency
Water Separator	Yes
Recommended fuel	#2 Diesel
Secondary Water Separator	Yes

Lubrication

Lubricating System	
Туре	Full Pressure
Oil pan capacity, L (qt.)	7.3 (7.7)
Oil pan capacity with filter, L. (qt.)	8.2 (8.7)
Oil filter: quantity, type	1, Cartridge
Oil cooler	Water-Cooled

Application Data

Cooling

Cooling	
Radiator System	
Ambient temperature, °C (°F)*	50 (122)
Engine jacket water capacity, L (gal.)	2.6 (0.7)
Radiator system capacity, including engine, L (gal.)	10.6 (2.8)
Engine jacket water flow, Lpm (gpm)	98 (26)
Heat rejected to cooling water at rated kW, dry exhaust, kW (Btu/min.)	35.7 (2030)
Heat rejected to air charge cooler at rated kW, dry exhaust, kW (Btu/min.)	10.9 (621)
Water pump type	Centrifugal
Fan diameter, including blades, mm (in.)	597 (23.5)
Fan, kWm (HP)	2.9 (3.9)
Max. restriction of cooling air, intake and discharge side of radiator, kPa (in. $\rm H_2O$)	0.125 (0.5)

^{*} Enclosure reduces ambient temperature capability by 5°C (9°F).


Operation Requirements

Air Requirements	
Radiator-cooled cooling air, m³/min. (scfm)‡	96 (3400)
Combustion air, m ³ /min. (cfm)	4.3 (152)
Heat rejected to ambient air:	
Engine, kW (Btu/min.)	14.0 (747)
Alternator, kW (Btu/min.)	7.6 (435)

‡ Air density = 1.20 kg/m³ (0.075 lbm/ft³)

Fuel Consumption			
Diesel, Lph (gph) at % load	Standby	Rating	
100%	16.2	(4.3)	
75%	12.1	(3.2)	
50%	8.5	(2.2)	
25%	5.0	(1.3)	
Diesel, Lph (gph) at % load	Prime !	e Rating	
100%	13.7	(3.6)	
75%	10.8	(2.9)	
50%	7.6	(2.0)	
25%	4.5	(1.2)	


Controllers



Decision-Maker® 550 Controller

Audiovisual annunciation with NFPA 110 Level 1 capability.
Programmable microprocessor logic and digital display features.
Alternator safeguard circuit protection.
12- or 24-volt engine electrical system capability.

Remote start, remote annunciation, and remote communication options. Refer to G6-46 for additional controller features and accessories.



Decision-Maker® 3+, 16-Light Controller

Audiovisual annunciation with NFPA 110 Level 1 capability.
Microprocessor logic, AC meters, and engine gauge features.
12- or 24-volt engine electrical system capability.
Remote start, prime power, and remote annunciation options.
Refer to G6-30 for additional controller features and accessories.

KOHLER CO., Kohler, Wisconsin 53044 USA Phone 920-565-3381, Fax 920-459-1646 For the nearest sales and service outlet in the US and Canada, phone 1-800-544-2444 KohlerPower.com Kohler Power Systems Asia Pacific Headquarters 7 Jurong Pier Road Singapore 619159 Phone (65) 6264-6422, Fax (65) 6264-6455

Additional Standard Features Alternator Protection (standard with 550 controller) Battery Rack and Cables Oil Drain and Coolant Drain w/Hose Barb Oil Drain Extension (with narrow skid and enclosure models only) Operation and Installation Literature Badiator Drain Extension (with enclosure only)	Paralleling System Reactive Droop Compensator Remote Speed Adjust Control/Electronic Governor Voltage Adjust Control Voltage Regulator Relocation Miscellaneous
 Battery Rack and Cables Oil Drain and Coolant Drain w/Hose Barb Oil Drain Extension (with narrow skid and enclosure models only) 	Remote Speed Adjust Control/Electronic Governor Voltage Adjust Control Voltage Regulator Relocation
 Run Relay Cooling System Block Heater; Recommended for Ambient Temperatures Below 0°C (32°F) Radiator Duct Flange Electrical System Alternator Strip Heater Battery Battery Battery Charger, Equalize/Float Type Battery Heater Line Circuit Breaker (NEMA type 1 enclosure) Line Circuit Breaker with Shunt Trip (NEMA type 1 enclosure) Safeguard Breaker (not available with 550 controller) 	NOTE: This drawing is provided for reference only and should not be used for planning installation. Contact your local distributor for more detailed information. DISTRIBUTED BY: